



NOTES:

- 1) Requires 2 conductor #24 AWG shielded cable Belden 9501 or equal up to 2000' in length. Ground shield at control panel end only. Insulate shield at sensor end.
- 2) Installation of a service valve for replacement and maintenance is strongly recommended. Attached electrical conduit must be fully supported - the sensor must not carry any of the conduit's weight. Avoid mounting in a prone position in which the sensor can be damaged or broken off.
- 3) Liquid pressure applications: WARRANTY WILL BE VOID if a pressure snubber is not used to prevent damage from hydraulic hammering.



© Copyright 2007 Logix® All Rights Reserved.		
CONFIDENTIAL: The information herein is confidential and may NOT be reproduced or divulged without the written permission of The Controls Group, Inc. LOGIX is a registered trademark of The Controls Group, Inc.		
Title Ashcroft T2 Pressure Sensor Wiring & Installation Detail Logix P/N SNR-059 and 060		
Date 01/26/07	Rev 01A	Drawn by MDG
Drawing Filename SNR-059-060 PressureT2.axd		